

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITORY  
CONDITION CERTIFICATE**

**NO. 08/2023**

**Date. 30/03/2023**

It is certified that an inspection team headed by MK Abdussalam, Health Inspector from CHC Olavanna Pantheerankave, inspected THE OXFORD SCHOOL, Pantheerankave on 29/03/2023 and found that the school has safe drinking water facilities for the students and members of staff of the institution and maintaining the hygienic condition in the school building and campus as per the norms prescribed by the central /state govt.

The above certificate is valid from 01/04/2023 to 31/03/2024.



Signature with seal

Name *Abdussalam m.k*

Designation *Health Inspector*

HEALTH INSPECTOR  
Community Health Centre  
Olavanna  
P.O. Pantheerankave  
Kozhikode-673019



Certificate No. TC-9551

## TEST REPORT

ULR No - TC955123000002940F

Date of report : 17/05/2023

Customer Name & Address	1.Date of Receipt	: 15/05/2023
OXFORD SCHOOL PANTHEERANKAVU C/O. SHAJAHAN (MANAGER) PANTHEERANKAVU KOZHIKODE	2.Sample Condition	: GOOD
	3.Sampling done by	: PARTY
	4.Sample code	: 2971
	5.Source of sample	: BORE WELL
	6.Sample quantity	: 1 LTR
	7.Test performing dates	: From : 15/05/2023 To: 16/05/2023


Sl No	Characteristics	Unit	Test Method	Acceptable limits as per IS:10500-2012	Result
1	Colour	Pt Co. unit	IS:3025(part 4) 2021	-	Not Done
2	Odour	-	IS:3025(part 5) 2018	Agreeable	Not Done
3	Taste	-	IS:3025(part 8) 1984	-	Not Done
4	Turbidity	(NTU)	IS:3025(part 10)1984	1	0.18
5	pH at 25°C	-	IS:3025(Part 11)2022	6.5 to 8.5	6.87
6	Alkalinity	(mg/Litre)	IS:3025(Part 23)1986	200	Not Done
7	Total Dissolved Solids(TDS)	(mg/Litre)	IS:3025(part 16)1984	500	20.0
8	Total Hardness (as CaCO <sub>3</sub> )	(mg/Litre)	IS:3025 (part 21)1998	200	8.0
9	Calcium (as Ca)	(mg/Litre)	IS:3025 (part 40)1994	75	Not Done
10	Magnesium (as Mg)	(mg/Litre)	IS:3025 (part 46)1994	30	Not Done
11	Chloride (as Cl)	(mg/Litre)	IS:3025 (part 32)1988	250	8.0

Remarks:- The results reported relate only to the sample received and tested. This test report shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed By: Chemist Hm  
HASANA-M

KWA/QC/KKD/F4

Issue No. 02



Authorized By : [Signature]

QUALITY MANAGER  
QUALITY CONTROL DISTRICT LAB  
KERALA WATER AUTHORITY  
KOZHIKODE



# KERALA WATER AUTHORITY

QUALITY CONTROL DISTRICT LAB

MALAPARAMBA, KOZHIKODE

Ph: 0495 2964751

E-mail : aeqedkzhikode@gmail.com

## TEST REPORT

Report No - KWA/KKD/2971/23

Date Of Report: 17/05/2023

Customer Name & Address	1.Date of Receipt	: 15/05/2023
OXFORD SCHOOL PANTHEERANKAVU C/O. SHAJAHAN (MANAGER) PANTHEERANKAVU KOZHIKODE	2.Sample Condition	: GOOD
	3.Sampling done by	: PARTY
	4.Sample code	: 2971
	5.Source of sample	: BORE WELL
	6.Sample quantity	: 1 LTR
	7.Test performing dates	: From : 15/05/2023 To: 16/05/2023

Sl. No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Electrical conductivity at 25°C	(micro mhos/cm)	IS 3025 (part 14)-2013		29.10
2	Acidity	(mg/litre)	IS 3025 (part 22)-1986		Not Done
3	Sulphate (as SO <sub>4</sub> )	(mg/litre)	IS 3025 (PART 24)-1986	200	Not Done
4	Phosphate [as PO <sub>4</sub> ]	(mg/litre)	IS 3025 (PART 31)-2008		ND
5	Fluoride (as F)	(mg/litre)	APHA 4500F-D 23rd Edition	1.0	Not Done
6	Iron (as Fe)	(mg/litre)	IS 3025 (part 53)-2003	1.0	0.06
7	Nitrate (as NO <sub>3</sub> )	(mg/litre)	APHA4500NO3-B 23rd Edition	45	4.56
8	Ammonia	(mg/litre)	IS 3025 (part 34)-2008	0.5	ND
9	Residual Chlorine	(mg/litre)	IS 3025 (part 26)-1986	0.2	Not Done

Remarks:- The results reported relate only to the sample received and tested. This test report shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed By: Chemist Hm  
HASANA-M

Authorized By :

QUALITY MANAGER

QUALITY CONTROL DISTRICT LAB  
KERALA WATER AUTHORITY

Rev.No. 00 Rev.Date : 00

\*End of Report\*

KWA/QC/KKD/F4

Issue No. 01

Issue Date :01/12/2020



# KERALA WATER AUTHORITY

QUALITY CONTROL DISTRICT LAB

MALAPARAMBA, KOZHIKODE

Ph: 0495 2964751

E-mail : aeqcdkozhikode@gmail.com

## TEST REPORT

Report No - KWA/KKD/2971/23

Date of Report: 17/05/2023

Customer Name & Address	1.Date of Receipt	: 15/05/2023
OXFORD SCHOOL PANTHEERANKAVU C/O. SHAJAHAN (MANAGER) PANTHEERANKAVU KOZHIKODE	2.Sample Condition	: GOOD
	3.Sampling done by	: PARTY
	4.Sample code	: 2971
	5.Source of sample	: BORE WELL
	6.Sample quantity	: 100 ML
	7.Test performing dates	: From : 15/05/2023 To: 16/05/2023

Sl. No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Coliforms	CFU/100 ml	IS 15185(part1) 2002 reaffirmed2016	Shall not be detectable in any 100ml sample	NIL
2	E coli	CFU/100 ml	IS 15185(part1) 2002 reaffirmed2016	Shall not be detectable in any 100ml sample	NIL

Remarks:- The results reported relate only to the sample received and tested. This test report shall not be reproduced except in full without the written approval of the Laboratory

Authorized By : Microbiologist



KWA/QC/KKD/RESULT/B

Issue No. 01 Issue Date :08/02/2021

Rev.No. 00

Rev.Date : 00